

1655 Scott Boulevard  
Santa Clara, California 95050-4169  
(408) 985-2400  
FAX No. (408) 296-3256  
Cable ULINC SANTA CLARA, CA



EX2625

May 21, 1998

Afcon  
South El Monte, CA

Fax No.: 1-626-444-3887

Attention: Mr. Randy Leonhardt

Subject: CPVC Pipe Hangers for Use With Southern Yellow  
Pine Wood

Dear Randy:

Presently, your CPVC pipe hangers have been tested in Douglas fir lumber. We have compared the structural characteristics of Southern Yellow Pine and Douglas Fir and find the structural characteristics to be comparable. Based on that information, the use of Southern Yellow Pine and Douglas Fir wood with your products should be similar.

Very truly yours,

GARRETT TOM (Ext. 32438)  
Associate Managing Engineer  
Engineering Services  
Section 315P

GT:ar  
wps10